



Skills requirement

- 1 The main components inside the distribution box, such as leakage circuit breakers, current transformers, etc., are not installed for the time being, and installation space is reserved.
- 2 The rated leakage operating current of each outgoing circuit leakage circuit breaker of the distribution box is 100mA, and the rated leakage operating time is 0.2S.
- 3 The outlet circuit at the bottom of the external distribution box should be equipped with an adapter bar to connect with the external cable, and the cable should not be directly connected to the switch connector.
- 4 The distribution box is floor-standing, and the structure should meet the rainproof requirements for outdoor work.
- 5 The external dimensions of the distribution box refer to 2000*600*500mm, and the four corners are fixed at a height of 200mm from the ground.
- 6 The isolation switch used for isolation should be equipped with a transparent protective cover. When installing an industrial waterproof socket, it should have a waterproof slope. The socket selection should be a designated product or a product with national compulsory certification in accordance with the technical requirements of the original drawing.
- 7 There should be a protective panel outside the electrical installation board in the cabinet, with only the operating handle exposed.
- 8 The distribution box must meet the requirements of the Russian electrical code.

借(通)用件登记
描 图
描 校
旧底图总号

底图总号					产品型号		装配图代号	序号		
签 字					总配电箱系统图		图样标记	数量	重量	比例
日期	设计	校对	审核	工艺			共 张	第 张	1:2	
	标记处数	更改文件号	签 名	日期						
			标准化	日期						