

Concentrate Recirculation

Page : 1/3

Project name			
Calculated by		Permeate flow/train	4.00 m3/h
HP Pump flow	8.23 m3/h	Raw water flow/train	5.33 m3/h
Feed pressure	15.3 bar	Permeate recovery	48.60 %
Feed temperature	12.0 °C(53.6°F)	Total system recovery	75.00 %
Concentrate recirculation	2.90 m3/h	Element age	2.0 years
Feed water pH	8.30	Flux decline %, per year	5.0
Chem dose, mg/l, 100 %	55.1 NaOH	Fouling factor	0.90
Specific energy	1.09 kwh/m3	SP increase, per year	7.0 %
Pass NDP	14.1 bar	Inter-stage pipe loss	0.207 bar
Average flux rate	26.9 l/mh		

Feed type

Brackish Well Non-Fouling

Pass - Stage	Perm. Flow m3/h	Flow / Vessel Feed m3/h	Conc m3/h	Flux l/mh	DP bar	Flux Max l/mh	Beta	Stagewise Pressure			Perm. TDS mg/l	Element Type	Element Quantity	PV# x Elem #
								Perm. bar	Boost bar	Conc bar				
1-1	2.1	8.2	6.2	27.7	0.3	27.8	1.15	0	0	15	4.2	CPA7-LD	2	1 x 2M
1-2	1.9	6.2	4.2	26.1	0.2	26.5	1.2	0	0	14.7	6.8	CPA7-LD	2	1 x 2M

Ion (mg/l)	Raw Water	Feed Water	Permeate Water	Concentrate 1	Concentrate 2
Hardness, as CaCO3	0.23	0.48	0.000	0.6	0.9
Ca	0.06	0.12	0.000	0.2	0.2
Mg	0.02	0.04	0.000	0.1	0.1
Na	122.50	316.47	1.522	421.3	614.4
K	0.00	0.00	0.000	0.0	0.0
NH4	0.10	0.17	0.001	0.2	0.3
Ba	0.000	0.000	0.000	0.0	0.0
Sr	0.000	0.000	0.000	0.0	0.0
H	0.00	0.00	0.000	0.0	0.0
CO3	0.04	17.28	0.000	20.0	44.9
HCO3	165.00	502.37	3.222	663.5	958.3
SO4	98.00	201.78	0.150	268.8	392.5
Cl	12.00	24.65	0.073	32.8	47.9
F	0.00	0.00	0.000	0.0	0.0
NO3	16.00	32.43	0.499	43.1	62.6
PO4	0.00	0.00	0.000	0.0	0.0
OH	0.00	0.02	0.000	0.0	0.0
SiO2	0.00	0.00	0.000	0.0	0.0
B	0.00	0.00	0.000	0.0	0.0
CO2	61.18	2.28	2.28	2.28	2.28
NH3	0.00	0.01	0.01	0.01	0.01
TDS	413.72	1095.32	5.47	1450.12	2121.23
pH	6.70	8.60	6.45	8.71	8.86

Saturations

	Raw Water	Feed Water	Concentrate	Limits
CaSO4 / ksp * 100, %	0	0	0	400
SrSO4 / ksp * 100, %	0	0	0	1200
BaSO4 / ksp * 100, %	0	0	0	10000
SiO2 saturation, %	0	0	0	140
CaF2 / ksp * 100, %	0	0	0	50000
Ca3(PO4)2 saturation index	0.0	0.0	0.0	2.4
CCPP, mg/l	-90.88	26.75	81.95	850
Langelier saturation index	-4.20	-1.54	-0.74	2.8
Ionic strength	0.01	0.02	0.03	
Osmotic pressure, bar	0.2	0.6	1.2	

Concentrate Recirculation

Page : 2/3

Project name			
Calculated by		Permeate flow/train	4.00 m3/h
HP Pump flow	8.23 m3/h	Raw water flow/train	5.33 m3/h
Feed pressure	15.3 bar	Permeate recovery	48.60 %
Feed temperature	12.0 °C(53.6°F)	Total system recovery	75.00 %
Concentrate recirculation	2.90 m3/h	Element age	2.0 years
Feed water pH	8.30	Flux decline %, per year	5.0
Chem dose, mg/l, 100 %	55.1 NaOH	Fouling factor	0.90
Specific energy	1.09 kwh/m3	SP increase, per year	7.0 %
Pass NDP	14.1 bar	Inter-stage pipe loss	0.207 bar
Average flux rate	26.9 lmh		

Feed type											Brackish Well Non-Fouling			
Pass -	Perm.	Flow / Vessel		Flux	DP	Flux	Beta	Stagewise Pressure			Perm.	Element	Element	PV# x
Stage	Flow	Feed	Conc			Max		Perm.	Boost	Conc	TDS	Type	Quantity	Elem #
	m3/h	m3/h	m3/h	lmh	bar	lmh		bar	bar	bar	mg/l			
1-1	2.1	8.2	6.2	27.7	0.3	27.8	1.15	0	0	15	4.2	CPA7-LD	2	1 x 2M
1-2	1.9	6.2	4.2	26.1	0.2	26.5	1.2	0	0	14.7	6.8	CPA7-LD	2	1 x 2M


Pass -	Element	Feed	Pressure	Conc	NDP	Permeate	Permeate	Beta	Permeate (Stagewise cumulative)				
Stage	no.	Pressure	Drop	Osmo.		Flow	Flux		TDS	Ca	Mg	Na	Cl
		bar	bar	bar	bar	m3/h	lmh						
1-1	1	15.3	0.14	0.7	14.6	1	27.8	1.13	3.7	0	0	1.041	0.05
1-1	2	15.2	0.12	0.8	14.3	1	27.3	1.15	4.2	0	0	1.158	0.056
1-2	1	14.8	0.09	1	13.9	1	26.5	1.17	5.9	0	0	1.643	0.079
1-2	2	14.7	0.07	1.2	13.6	1	26	1.2	6.8	0	0	1.904	0.092

Concentrate Recirculation

Project name

Temperature : 12.0 °C

Page : 3/3
Element age, P1 : 2.0 years



Stream No.	Flow (m3/h)	Pressure (bar)	TDS (mg/l)	pH	Econd (µs/cm)
1	5.33	0	414	6.70	596
2	8.23	0	1095	8.60	1521
3	8.23	15.3	1095	8.60	1521
4	8.23	15.3	1095	8.60	1521
5	6.18	15.0	1450	8.71	1943
6	4.23	14.7	2121	8.86	2734
7	2.90	0	2121	8.86	2734
8	1.33	0	2121	8.86	2734
9	2.05	0	4.16	6.33	5.30
10	1.95	0	6.84	6.55	8.50
11	4.00	0	5.47	6.45	6.80